





Hosted by Paul Webber paul@webbertraining.com www.webbertraining.com










What should we do now?

✓■UTMB Infection Control Response to thurricane the



#### **Assessment of Surfaces**

#### Question?

 Did the storm cause bacteria and fungi to grow on the environmental surfaces of the hospital that were not wet from storm water or effected by wind?

**UTMB** 

Infection Control Response to Hurricane Ike

#### **Assessment of Surfaces**

- All environmental sites were first cleaned with a hospital grade disinfectant (quaternary ammonium)
- Beds, chairs, monitors, IV poles, headwalls etc were all cultured with a moistened swab
- The swabs were plated on media for bacteria and fungi.

**UTMB** 

fection Control Response t

20

#### Assessment of Surfaces

- We cultured 500 sites
- We found very few pathogenic bacteria (primarily gram negative rods) and fungi
- We concluded that the storm had little impact on the environmental surfaces in the hospital

**UTMB** 

Infection Control Response to Hurricane Ike

#### **Water Assessment**

The water in the hospital plumbing remained stagnant for several weeks.

#### Question?

- Did the stagnant water support the growth of bacteria, fungi or legionella?
- Did a glycocalyx in the pipes support the growth of the bacteria, fungi and legionella?

**UTMB** 

21

Infection Control Response to Hurricane Ike 22

#### Water assessment: bacteria

- Random samples of bacteria were taken from the clinical areas
- Threshold for bacteria was <50 cfu/ml</li>
- Results: most unit based handwashing sinks and bathroom sinks had bacteria >50 cfu/ml
- Faucets were flushed (purged) for 5 to 30 minutes over several weeks and periodically cultured
- Eventually bacteria were found to be below the threshold

JUTMB

Infection Control Response to Hurricane Ike

#### Water-assessment: fungi

- The same water sampled for bacteria was sampled for fungi
- The fungal growth was so infrequent that the assessment was discontinued

**∀**UTMB

Infection Control Response to Hurricane Ike 24

#### Water-assessment: Legionella

- When 30% of water samples taken from outlets (faucets) of the water distribution system are culture positive for Legionella, patients are at risk for Legionella infection.
- 10 unique hot water samples are suggested from each water system
- Results: samples showed > 30% of water cultured from all three buildings had legionella pneumophilia type 1

**UTMB** 

Infection Control Response to Hurricane Ike

#### Water Remediation: Legionella

#### Super heating

- Bring temperature in all pipes to 60°-77°C
- . Water should remain in pipes 20-30 minutes
- . Take temperature at distal end of the faucet
- . Dead legs can significantly effect results
- Must flush all faucets in the building after superheating
- Care should be taken not to scald patient and employees with hot water
- . Process may not offer long-term remediation

**UTMB** 


## Water remediation: Legionella

- Chlorine dioxide
- Infuse it into the system by professional
- · Required to sit in system until chemical diffuses to distal end for about 1 hour
- . CIO2 test strips or spectrophotometer test to assure chemical is at distal end
- Must flush all faucets in building to eliminate residual chemical



Infection Control Response to

#### Water Remediation: Chlorine dioxide



Chlorine dioxide (CIO2) can be generated by an electrolytic method from sodium chlorite (NaClO2)

**UTMB** 

Infection Control Response to

28

#### Water Remediation: Chlorine dioxide Notice / **AVISO**

- NOTICE DO NOT USE WATER
- MAINTENANCE ON THE HOT & COLD WATER SYSTEM IS OCCURRING RIGHT
- NOW
  MAINTENANCE WILL END WHEN THIS
  SIGN IS REMOVED
  Do not drink the water (Free Bottled
  Water is available from your dept.
- water is available from your dept.
  manager)
  Do not use the showers or turn on
  shower for any reason
  Do not wash hands or come in contact
  with water
- Do <u>not</u> turn off the water in the event water is running Flushing toilets and urinals is okay
- Please cooperate with the Techni
- THANK YOU for Your Help!!!

- AVISO
  NO USE EL AGUA
  EL MANTENIMIENTO DEL SISTEMA DE
  AGUA FRÍA Y CALIENTE ESTÁ EN
  PROCESO AHORA
- EL MANTENIMIENTO TERMINARÁ CUANDO EL AVISO SEA REMOVIDO
- CUANDO EL AVISO SEA REMOVIDO
  No tome aqua el agua embotellada es
  gratis y disponible con su gerente de
  departamento.)
  No use las regaderas o abra las llaves de
  la regadera por iniguna razón
  No se lave las manos o tenga contacto
  con el agua
  No cierre la llave del agua en caso de que
  esté abierta
  Pueda ialar las nalancas del inodoro o

- Puede jalar las palancas del inodoro o mingitorio
- Por favor coopere con los técnicos

¡GRACIAS por su cooperación!

JUTMB

Infection Control Response to Hurricane Ike


#### Water remediation: Copper Silver Ionization


- . Attach an ionizer to the hot water system
- . The ionizer sends a steady stream of copper and silver ions into the water
- . Copper and silver are known to have antibacterial properties
- The number of sites positive for legionella bacteria should be reduced to < 30%


**UTMB** 


Infection Control Response to Hurricane Ike

30















Hosted by Paul Webber paul@webbertraining.com www.webbertraining.com



#### Air Quality Assessment : fungi

- Air cultures were taken with an high volume air sampler called a Casella (flow rate 700 l/min)
- Air cultures were also taken with an air sampler called a SAS (flow rate 180 l/min)
- Thresholds in the OR are <3cfu/m³ and no pathogenic fungi such as A. fumigatus, A. flavus, A. terreus, or Zygomycetes or Fusarium
- Thresholds in the patient care areas are <15 cfu/m³ and minimum pathogenic fungi

**UTMB** 

fection Control Response I

20

#### Air Quality: Remediation

- · Air ducts were cleaned
- · Turning veins were cleaned
- · Fan coils were cleaned
- · Condensation pans were cleaned
- Filters were replaced and gaskets changed
- Filters were upgraded
- · Air systems were rebalanced

**UTMB** 

Infection Control Response to Hurricane Ike

### Air Quality: Epidemiology

- Air samples were taken twice a week
- Results were immediately fed back to a committee
- Experts were consulted about cleaning, filter choices and air balancing

**UTMB** 

Infection Control Response to Hurricane Ike

Air Quality: Containment

Infection Control Response to Hurricane like


41




Hosted by Paul Webber paul@webbertraining.com www.webbertraining.com











# After Ike we were concerned about surface, water and air contamination. Surfaces were successfully cleaned with a hospital-grade disinfectant. Bacteria and fungi in the water were successfully removed by constant flushing of the system. Legionella remediation is an ongoing project (Many institutions have a constant flow of copper silver ions to decontaminate the water). Air quality drastically improved after the ducts were cleaned and breaches in the ventilation system were repaired.

